


LACV-30 AUXILIARY POWER UNIT AIR FILTER(U) ARMY BELVOIR 1/1
RESEARCH DEVELOPMENT AND ENGINEERING CENTER FORT
BELVOIR VA J A YESCAVAGE ET AL JAN 88 BRDEC-2456

F/G 13/11

NL



AD-A192 237

AD

DTIC FILE COPY

technical Report



United States Army
Belvoir Research, Development & Engineering Center
Fort Belvoir, Virginia 22060-5606

REPORT 2456

LACV-30
Auxiliary Power Unit
Air Filter

DTIC
ELECTE
MAR 18 1988
S D

James A. Yescavage
Authored By: Jonathan D. Ives

Report Date: January 1988

Approved for public release; distribution unlimited.

88 3 17 030

Destroy this report when it is no longer needed. Do not return it to the originator.

The citation in this report of trade names of commercially available products does not constitute official endorsement or approval of the use of such products.

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE

REPORT DOCUMENTATION PAGE				Form Approved OMB No 0704-0188 Exp Date Jun 30, 1986	
1a REPORT SECURITY CLASSIFICATION Unclassified			1b RESTRICTIVE MARKINGS None		
2a SECURITY CLASSIFICATION AUTHORITY NA			3 DISTRIBUTION/AVAILABILITY OF REPORT Approved for public release; distribution unlimited.		
2b DECLASSIFICATION/DOWNGRADING SCHEDULE NA					
4 PERFORMING ORGANIZATION REPORT NUMBER(S) 2456			5 MONITORING ORGANIZATION REPORT NUMBER(S) NA		
6a NAME OF PERFORMING ORGANIZATION Belvoir RD&E Center Logistics Support Directorate		6b OFFICE SYMBOL (If applicable) STRBE-FRD	7a NAME OF MONITORING ORGANIZATION TECOM		
6c ADDRESS (City, State, and ZIP Code) Marine Division Fort Belvoir, VA 22060-5606			7b ADDRESS (City, State, and ZIP Code) Aberdeen Proving Ground, MD 21005		
8a NAME OF FUNDING/SPONSORING ORGANIZATION NA		8b OFFICE SYMBOL (If applicable) NA	9 PROCUREMENT INSTRUMENT IDENTIFICATION NUMBER 13227E9265		
8c ADDRESS (City, State, and ZIP Code) NA			10. SOURCE OF FUNDING NUMBERS		
			PROGRAM ELEMENT NO. NA	PROJECT NO. NA	TASK NO. NA
			WORK UNIT ACCESSION NO. NA		
11 TITLE (Include Security Classification) LACV-30 AUXILIARY POWER UNIT AIR FILTER (Unclassified)					
12 PERSONAL AUTHOR(S) James A. Yescavage and Jonathan D. Ives					
13a TYPE OF REPORT Final		13b TIME COVERED FROM 1984 TO 1987		14 DATE OF REPORT (Year, Month, Day) January 1988	
15 PAGE COUNT 42					
16 SUPPLEMENTARY NOTATION NA					
17 COSATI CODES			18. SUBJECT TERMS (Continue on reverse if necessary and identify by block number)		
FIELD	GROUP	SUB-GROUP	Permakleen TM Air Cleaner System ←		
19. ABSTRACT (Continue on reverse if necessary and identify by block number)					
<p>This technical report presents Belvoir RD&E Center analysis of and proposed solution to problems (severe clogging, fire hazards, high replacement costs, maintenance requirements) caused by paper air filters on the gas turbine Auxiliary Power Unit (APU) on the LACV-30. The proposed LACV-30 replacement filters have three stages of cleaning: an inertial separator, a mist eliminator pad, and a foreign object damage (FOD) screen. The new filter decreases the need for spare parts and extensive maintenance, extends the life and efficiency of the APU, and increases horsepower by 3%. This report contains the contractor's (Pall Corporation) Technical Proposal and Field Performance Study.</p>					
20 DISTRIBUTION/AVAILABILITY OF ABSTRACT <input checked="" type="checkbox"/> UNCLASSIFIED/UNLIMITED <input type="checkbox"/> SAME AS RPT <input type="checkbox"/> DTIC USERS			21 ABSTRACT SECURITY CLASSIFICATION Unclassified		
22a NAME OF RESPONSIBLE INDIVIDUAL James A. Yescavage			22b TELEPHONE (Include Area Code) 703/664-5498		22c OFFICE SYMBOL STRBE-FRD

DD FORM 1473, 84 MAR

83 APR edition may be used until exhausted
All other editions are obsoleteSECURITY CLASSIFICATION OF THIS PAGE
Unclassified

PREFACE

Testing of replacement filters was conducted during May and June 1986 at Fort Story, Virginia, to determine if these filters provided an acceptable solution to problems caused by paper air filters on the gas turbine Auxiliary Power Unit (APU). The problem areas included severe clogging, fire hazards, high replacement costs, and maintenance requirements.

The LACV-30 replacement filter has three stages of cleaning:

1. An inertial separator;
2. A mist eliminator pad; and
3. A foreign object damage (FOD) screen.

This clean, reusable filter system decreases the need for spare parts and extensive maintenance, extends the life and efficiency of the APU, and increases horsepower by 3 percent.

This report includes the original technical proposal of the LACV-30 filter (Appendix A), and documented testing procedures and results (Appendix B).



Accession For	
NTIS CRA&I	<input checked="checked" type="checkbox"/>
DTIC TAB	<input type="checkbox"/>
Unannounced	<input type="checkbox"/>
Justification	
Ex	
Distribution	
Availability Codes	
Dist	Availability or Special
A-1	

CONTENTS

	Page
Section I Background.....	1
Section II Analysis.....	2
Section III Results and Conclusions.....	4
Appendix A Technical Proposal, Pall Land and Marine Corporation, dated 04-27-84.....	A-1
Appendix B Field Performance Study, Pall Corporation, dated 08-06-86.....	B-1

SECTION I. BACKGROUND

The Lighter, Air Cushion Vehicle, 30-ton (LACV-30) is a high-speed aircraft capable of carrying 30 tons of cargo over water, land, ice, and marginal terrain. The primary mission of the LACV-30 for the US Army is the transport of containerized and wheeled cargo from supply ship to shoreside marshalling areas in support of logistics over-the-shore (LOTS) operations. The LACV-30 can also be used in such missions as ice breaking, search and rescue, and other coastal, harbor, and inland waterway roles.

It is the purpose of this report to outline problems with the existing paper barrier air filter for the LACV-30 Auxiliary Power Unit (APU) and to present recommendations for its replacement. The principles of air cushion vehicle operations, coupled with the amphibious nature of the LACV-30's mission, subjects the air intake system to excessive ingestion of sand and salt water mist. This necessitates a reliable air cleaning system to protect the five gas turbine engines which power the LACV-30.

The LACV-30 is powered by four (i.e. two twin pack) Pratt & Whitney ST-6 turbine engines. The Auxiliary Power Unit (APU) is an Alturdyne/Solar "Titan" gas turbine rated at 140 horsepower at 3,600 shaft rpm.

The air intake system for the four main propulsion engines and the APU was originally configured to pass all air through two Donaldson centrifugal separator type air cleaners. A portion of the cleaned air was diverted to the APU through about 12 feet of duct and a battery box to the plenum which was fitted with a barrier filter (Donaldson P/N P14-2243, with paper filter medium) as a final protection for the APU turbine against particulate contamination.

The problem with the original system was that the barrier filter in the plenum of the APU clogged after 5 to 15 hours of normal operation. Once the filter became clogged, the engine drew in hot exhaust gas, thereby creating a fire hazard in the APU.

SECTION II. ANALYSIS

In light of the high cost of replacement and fragile nature of the paper type air filter, in addition to the fire hazard it produces, an interim filter—a 140 microns stainless steel screen—was used on the LACV-30 until a permanent solution could be achieved. However, the interim filter does not provide the long-term protection which the gas turbine APU requires.

It was proposed by Pall Land and Marine Corporation, a subsidiary of Pall Corporation, that a Permakleen™ Air Cleaner System to be utilized as a solution to the problems at hand. This system includes a mist eliminator which will aid in the removal of salt mist. This is necessary since inertial type precleaners are not effective in separating mist. The mist eliminator is shown in Figure 1, and the inertial separator in Figure 2. Appendix A contains the technical proposal for this system and details the advantages of the Permakleen™ system over the original system. (For a schematic of this system, see Appendix A, page A-8).

It was decided to install the Permakleen™ system on LACV-30-01 as a prototype to determine the feasibility of installation and to enable testing of the system under operating conditions. Evaluation of the new system was conducted by Pall Corporation Scientific and Laboratory Services Department. An isokinetic sampling device was used to capture particles in an ultraclean fluid using the principle of high velocity impingement at the inlet and outlet of the Permakleen™ system under both land and ocean/beach operating conditions. Particles captured in the fluid were counted, and a sodium analysis was also conducted on the oil in the impingers to estimate ingress of sea salt during the ocean/beach run. A complete report (written by Pall Corporation) of the field performance study conducted is provided in Appendix B.




Figure 1.




Figure 2.

SECTION III. RESULTS AND CONCLUSIONS

The number of particles per cubic foot of air was calculated from the particle counting analysis in the inlet and outlet impingers. Based on these results, the Permakleen™ air cleaner was filtering more than 99.9 percent of the solid particles greater than 10 microns introduced at inlet operating over land.

Concerning the ocean/beach run, analysis of the oil samples for total sodium content shows that levels were reduced about 2.65 times from the air inlet to the system. Based on the average level of sodium in sea water, this equates to a 0.07 milliliter of sea water taken in by the APU turbine per cubic foot of air.

Due to the problems with the original air filtering system and the fact that the interim does not meet the protection requirements of the gas turbines, a new air filtering system is necessary and should be obtained and installed before time consuming and costly damage to the turbines is incurred. The Permakleen™ Air Cleaner System is one system meeting the turbine requirements and could be utilized.

APPENDIX A

TECHNICAL PROPOSAL

PERMAKLEENTM


INLET AIR CLEANER SYSTEM

FOR
LACV-30 APU

P/N CJ-00125-1

LOG NO. 012902


CHARLES ROACH


CEDRIC SUN

APRIL 27, 1984

PALL LAND AND MARINE CORP.

A SUBSIDIARY OF PALL CORPORATION

7070 MOON LAKE ROAD • NEW PORT RICHEY, FL 33552 • (813) 849-9999


PALL

PLUSA

April 27, 1984

TABLE OF CONTENTS

	PAGE
INTRODUCTION AND SUMMARY	1
SYSTEMS DESCRIPTION	2
DISCUSSION	3 - 6
PERMAKLEEN TM AIR CLEANER SYSTEM	6 - 10
PROGRAM SCHEDULE	10
F.O.D. SCREEN	APPENDIX A
"CENTRISEP AIR CLEANER SYSTEM"	ENCLOSURE 1
SHIN MEIWA AIR CLEANER/MIST ELIMINATOR TEST REPORT (APM-138)	ENCLOSURE 2
APPLICATION NEWS (PLM-118)	ENCLOSURE 3
APPLICATION NEWS (PLM-117a)	ENCLOSURE 4
PALL ANUAL REPORT	ENCLOSURE 5
PLM PROPOSAL DRAWING CJ-00125-1	

1.0 INTRODUCTION AND SUMMARY

Pall Land and Marine Corporation (PLM), a subsidiary of Pall Corporation, hereby submits its unsolicited proposal for an extended service life air filter and salt mist eliminator system to overcome the LACV-30 APU inlet air filtration problems.

The proposed PermaKleenTM Air Cleaner System is an unitized assembly consisting of a self-cleaning inertial precleaner in series with a stainless steel recleanable depth type filter/demister element offering:


- ° Extended service life
- ° Salt mist removal
- ° Handles moisture laden air with no pressure rise
- ° Filter/demister element is easily cleanable and resistant to handling damage

The PermaKleenTM System can be retrofitted with minimal changes.

2.0 SYSTEMS DESCRIPTION

2.1 Present System


Figure 1 is a diagram of the current air flow into the APU. Filter is a cylindrical pleated paper element.



PRESENT SYSTEM
FIGURE 1

2.2 Proposed System

Figure 2 represents proposed PermaKleenTM Air Cleaner System.




PROPOSED PERMAKLEENTM AIR CLEANER SYSTEM
FIGURE 2

3. Pleated cellulose paper barrier filters have relatively short service life. Further, wet or moisture laden air can cause high flow restriction even in a clean filter element.
4. Paper filters are easily damaged during cleaning and servicing.

3.2 Proposed PermaKleenTM Air Cleaner Assembly

We propose our PermaKleen System; an unitized assembly replacing the current "shared" pre-cleaner and paper barrier filter.

Key components of this assembly consist of a dedicated self-cleaning precleaner and a field cleanable depth filter/demister element (see also Figure 7, Page 8).



PERMAKLEENTM AIR CLEANER ASSEMBLY
FIGURE 4

Please refer to enclosed proposal Drawing No. CJ-00125-1 for detail dimensions and performance values. Proposed configuration assumes a minimum of 8 inches water column static head is available at the pre-cleaner inlet.


Separation efficiency and overall air flow resistance will be comparable to the existing system. Primary advantages over the present system are:

- ° Three to eleven times service life.
- ° Salt mist removal down to 2 microns.
- ° Provides filtered and demisted air to generator and compartments.
- ° No flow resistance increase in presence of wet or moisture laden air.

We propose to locate the air cleaner assembly beneath the inlet elbow of the vane axial blower; with the following modifications:

1. Remove the air duct (Y Section) leading from the main engine precleaners up to approximately one foot from the APU compartment inlet. Blank off the two precleaner discharge ports.
2. Place the air cleaner assembly below the vane axial blower elbow parallel with its flow axis.
3. Fabricate a new duct connecting from a point at the vane axial blower discharge plenum to the air cleaner assembly inlet. Connect the outlet to the APU compartment inlet duct.
4. Remove the paper barrier filter and holder bracket. Enlarge the APU inlet plenum opening to maximum dimensions and install a f.o.d. screen. (See Sketch Appendix A.)

Figure 5 depicts the PermaKleen System in place.



PERMAKLEEN™ SYSTEM INSTALLATION
FIGURE 5

4.0


PERMAKLEEN AIR CLEANER SYSTEM

The proposed Permakleen Air Cleaner System is represented by the enclosed proposal Drawing No. CJ-00125-1. It is an unitized assembly consisting of:

1. Rectangular housing with appropriate inlet and outlet transitions to round ducting.
2. Within the housing is a permanently fixed multitube precleaner and a removable filter/demister element. The latter slides out for cleaning.

4.1 Precleaner

The precleaner is a flat panel made up of an array of precleaner tubes.




PRECLEANER TUBE
FIGURE 6

Dust and moisture laden air entering the precleaner tube is imparted a swirling motion induced by the vortex generator. This swirling motion causes dirt particles and water droplets to be centrifuged toward the wall of the tube. They are then scavenged overboard with a small portion of the inlet air. In a pressurized system, scavenge flow rate is controlled by discharge orifices in the housing. Cleansed air located within center of the vortex proceeds through the outlet.

Design of the precleaner is same as PLM's self-cleaning Centrisep Air Cleaners used to protect helicopter turbine engine inlet air. It was first installed on Army's OH-58 "KIOWA" Helicopter. This was followed by other helicopter models working in severe dust environments. Please refer to enclosure 1 titled "Centrisep Air Cleaner Systems" for background information.

The precleaner has a gravimetric dust separation efficiency of 92% (AC Coarse Test Dust). This is approximately equivalent to particle size cut off at 25 microns. It by itself, will not adequately protect a gas turbine operating predominantly in highly contaminated environments. Therefore, a filter/demister element is placed downstream (see Figure 7) to capture fine dust particles and salt spray mist down to 2 microns.



PERMAKLEENTM AIR CLEANER SYSTEM
FIGURE 7

4.2 Filter/Demister

The filter/demister hereafter referred to as the "element" is a 4.5 inch thick panel made up of looped stainless steel wire filament matrix. An oil film of MIL-L-23699 or equivalent covers the filter filaments.

Fine dirt particles are collected on the filament surfaces. Most of the dirt is collected within the first 2 to 3 inches of element depth. When filament surfaces are saturated, design pressure drop is reached. The panel should be removed for cleaning.

Unlike paper barrier type filters whose media are typically less than 0.020" thick, the filter/demister element is 4.5" thick. It cannot be easily punctured during cleaning and servicing. For example, pushing a nail into the panel has no appreciable effect on dust collection efficiency.

Salt spray mist impact and agglomerate on the wire filament matrix. Water is drained off. Under low humidity conditions, water evaporates leaving salt behind.

4.3 Separation Efficiencies

Overall separation efficiency of the PermaKleen Air Cleaner System is 99% (AC Coarse Test Dust). This compares favorably with 98.8% of the present paper barrier filter. The latter efficiency was based on our test of a pleated paper element removed from a vehicle at Fort Story. A separate laboratory report will be submitted.

The PermaKleen System is a good demister. A precleaner and 4" thick element was tested at the Naval Air Propulsion Center in 1980, using synthetic sea water per MIL-E-5009C. Test conditions unitized input concentrations of approximately 0.1, 1, 10, and 100 ppm salt-to-air ratio by weight for three relative humidity ranges. Salt removal was effective down to 2 microns.

A very severe simulated laboratory salt spray test was run by Shin Meiwa Industry, LTD. of Japan. It was performed on a system with a 2" thick filter/demister panel (as compared to 4.5" proposed). Based on the results, our system is now on board the PS-1/US-1 Flying Boat protecting the onboard AiResearch Garrett gas turbine APU. Copy of this report Publication No. APM-138 is enclosed (Enclosure 2). Two illustrations of airborne systems protecting gas turbines are shown in Enclosures 3 and 4.

TP/APU

4.4 Cleanability

The precleaner panel can be cleaned by hosing with water from both the front and back faces. Loose dirt and salt water trapped within the panel will self-purge on next start up.


The filter/demister element can be readily cleaned by hosing with water and detergent. This to be followed by spraying with engine lubricating oil MIL-L-23699 or equivalent.

5.0 PROGRAM SCHEDULE

Design parameters and hardware configuration for this proposal were based on verbal inputs and onsite observations. They need to be confirmed. It can also be obtained by making field measurements on an operating vehicle. Milestone Chart below assumes all data for firm design is made available.

PROGRAM SCHEDULE

PART NO. CE-00125-1
PROGRAM SCHEDULE
WEEKS AND




Pricing will be submitted separately.


A copy of Pall Corporation Annual Report is enclosed (Enclosure 5). Specific references to PLM are shown on Pages 19 to 21.

TR/ADU

APPENDIX "A"



F.O.D. SCREEN



NO.	DESCRIPTION	P/N
11	BARrier FILTER	P12-506 (DONALDSON)
12	REF MODIFICATION TO INLET	4-428105
14	POWER MODULE	2-1640953
16	REF MODIFICATION STEP WALK AND LADDER	2-181062
18	OUTER DUCT	2-181055 (DONALDSON)
19	WIRE MESH SCREEN (BELOW DECK)	2-181051
20	FLEXIBLE SLEEVE	2-181054
21	INNER DUCT	2-181053
22	DUCT AFT	4-428110
23	DIFFUSER INSTALLATION - FAN EXIT	

AIR MANAGEMENT SYSTEM INSTALLATION 4-428001

NO.	DESCRIPTION	P/N
1.	AUXILIARY POWER UNIT	T62 32 (ISOLAR)
2.	FAN AND APU INSTALLATION	4-428002
3.	AUXILIARY FAN	MODEL 29 89 TYPE 3 (BUFFALO FORCE)
4.	DUCT ASSY (FILTER TO POWER MODULE)	4-428090
5.	PLENUM ASSEMBLY	4-428093
6.	SHUTTER INSTALLATION	4-428178
7.	DUCT-FILTER TO FILTER	4-428089
8.	AIR CLEANER	6179M1068 (DONALDSON)
9.	AGGLOMERATOR ASSEMBLY	4B 23220 (PEERLESS)
10.	MIST EXTRACTOR	4-428126
	REF MODIFICATION	

Figure 2-9-1. Air Management System

APPENDIX B

Pall Corporation

30 Sea Cliff Avenue · Glen Cove, N.Y. 11542 · USA
Phone 516-671-4000 · TWX 510 223 0606
Telex 126329 · Cable Pallco Glen Cove

SCIENTIFIC & LABORATORY SERVICES DEPT.

Director: Erwin Kirnbauer

FILTER PERFORMANCE TESTS

PROCESS & SYSTEM CONTAMINATION CONTROL

PARTICULATE & MICROBIAL FLUID CONTAMINATION ANALYSIS

WEAR ANALYSIS

BIOLOGICAL CONTROLS

August 6, 1986

SLS Report #1787

Revision A

A Field Performance Study of a PLM Permakleen™ Air
Cleaner System Serving the APU of an LACV-30 for the
U.S. Army, Fort Belvoir, Virginia

(Rev. A)

Purpose

This study was conducted at the request of the U.S. Army to determine levels of particulate and sea salt contamination in the air stream at the inlet and outlet of the PLM Permakleen™ Air Cleaner System during operation of the LACV-30 over land and over ocean/beach at Fort Story, Virginia.

(Rev. A)

Summary

An isokinetic sampling device was used to capture particles in an ultraclean fluid using the principle of high velocity impingement. Particles captured in the fluid were counted. Sodium analysis was also conducted on the oil in the impingers to estimate ingress of sea salt during the ocean/beach run.

Owing to expected variations in conditions during sampling in the field the results of analysis reported here are relied on only to show approximate levels and gross differences in the particulate/sea salt levels at the inlet and outlet of the PLM Permakleen™ Air Cleaner System.

The results of analysis show that the Permakleen™ Air Cleaner System is performing properly to remove greater than 99.9% of particles ingressing into the air intake system of the auxiliary power unit (APU) turbine.

Sea salt ingress levels were low (~ 0.2 milliliters sea water equivalent/ft³) at the system inlet. These levels were found to be about 2.65 times lower at the outlet of the Permakleen™ system (~ 0.07 milliliters sea water equivalent/ft³).

Based on the performance of the Permakleen™ Air Cleaner System it is recommended that this system be implemented on all LACV-30 craft as the air intake filtration system for the APU.

Scientific & Laboratory Services Dept.

Background

The LACV-30 is a Light Amphibious (Air Cushion Vehicle) commissioned by the U.S. Army. The LACV is powered by four (i.e. two twin pack) Pratt & Whitney PT-6 turbine engines. The Auxiliary Power Unit (APU) is an Alturdyne/Solar "Titan" gas turbine rated at 140 hp @ 3600 shaft rpm.

The air intake system for the four main propulsion engines and the APU was originally configured to pass all air through two Donaldson centrifugal separator type air cleaners. A portion of the cleaned air was diverted to the APU through about 12 feet of duct and a battery box to the plenum which was fitted with a barrier filter (Donaldson P/N P14-2243, with paper filter medium) as a final protection for the APU turbine against particulate contamination. (Rev.)

The problem with the original system was that the barrier filter in the plenum of the APU clogged after about 10 hours of operation. (Rev. A)

Appendix A is a schematic of the Permakleen™ Air Cleaner System proposed by Pall Land and Marine (PLM) Corporation to provide a low maintenance, high efficiency air cleaner for the APU in place of the original barrier filter. It should also be noted that the air entering the Permakleen® air cleaner does not first pass through the Donaldson inertial air cleaner.

The Permakleen™ Air Cleaner System was installed on LACV-30 craft No. 1 in December, 1985. Sampling and analysis of particulate contamination levels in the air stream at the inlet and outlet of the Permakleen™ unit was requested by the U.S. Army to demonstrate performance of the system in-service on LACV-30, craft No. 1, at Fort Story, Virginia. The sampling was conducted by Pall Scientific and Laboratory Services (SLS) Department on June 17, 1986.

Appendix B provides description of the sampling device used and the conditions of sampling.


Analytical Procedures

(See Appendix C)

Test ResultsContamination Levels In Impingers

The MIL-H-5606 in each impinger sampler (A, B, C and D) was particle counted. The results of particle counting are reported in the Table below as the total number of particles per impinger. Analytical membranes were prepared for photomicrographing representative contaminant particles in equal volumes of oil from sampling impingers A, B, C and D. These photomicrographs are shown in Figures I through IV. Figure V is a photomicrograph of original, clean MIL-H-5606 which was used to fill the impingers in preparation for the sampling.


FIGURE 1



- IMPINGER A -
LAND RUN
- INLET -

This photomicrograph depicts contaminants filtered from 25 milliliters of sample oil from impinger A onto a $0.8\mu\text{m}$ (25 mm diameter) analysis membrane. The magnification is 100X. The scale is $13.6\mu\text{m}/\text{div}$.

FIGURE II




This photomicrograph depicts contaminants filtered from 25 milliliters of sample oil from impinger B onto a 0.8µm (25 mm diameter) analysis membrane. The magnification is 100X. The scale is 13.6µm/div.

FIGURE III

- IMPINGER C -
BEACH/OCEAN RUN
- INLET -

This photomicrograph depicts contaminants filtered from 25 milliliters of sample oil from impinger C onto a $0.8\mu\text{m}$ (25 mm diameter) analysis membrane. The magnification is 100X. The scale is $13.6\mu\text{m}/\text{div}$.

FIGURE IV



- IMPINGER D -
BEACH/OCEAN RUN
OUTLET OF PERMAKLEEN

This photomicrograph depicts contaminants filtered from 25 milliliters of sample oil from impinger D onto a 0.8 μ m (25 mm diameter) analysis membrane. The magnification is 100X. The scale is 13.6 μ m/div.

FIGURE V

ORIGINAL - CLEAN
MIL-H-5606
USED TO CHARGE
IMPINGERS
A, B, C and D

This photomicrograph depicts contaminants filtered from 25
milliliters of original, clean MIL-H-5606 onto a $0.8\mu\text{m}$ (25 mm diameter)
analysis membrane. The magnification is 100X. The scale is
 $13.6\mu\text{m}/\text{div}$.

Scientific & Laboratory Services Dept.

Impingers Particle Counts in Total Volume of MIL-H-5606 in Impinger (Rev. A)

<u>Land Run</u>	<u>1 to 5μ</u>	<u>5 to 15μ</u>	<u>10 to 15μ</u>	<u>15 to 50μ</u>	<u>25 to 50μ</u>	<u>50 to 100μ</u>	<u>>100μ</u>
-----------------	-------------------------------	--------------------------------	---------------------------------	---------------------------------	---------------------------------	----------------------------------	--------------------------------

A	31,424,923.0	6,074,155.3	5,260,238.3	575,180.8	265,780.0	20,043.1	2,123.5
B	242,203.0	8,567.0	728.0	1,898.0	676.0	182.0	13.0

Ocean/Beach Run

C	177,992.5	39,550.0	12,670.0	7,420.0	2,432.5	1,155.0	297.5
D	82,841.0	10,200.0	1,496.0	3,111.0	2,023.0	663.0	136.0

Water Analysis

The total water contents of original condition MIL-H-5606, and samples of this oil in the used impingers from the beach/ocean run (i.e. impingers C and D) were determined using the Karl Fischer method.

<u>Samples Oil (MIL-H-5606)</u>	<u>Total Water (ppm by weight)</u>
-original oil	80
-oil from used impinger C	84
-oil from used impinger D	82

Total Sodium Analysis

Total sodium content was determined for original MIL-H-5606, original MIL-L-23699* and oil from each used impinger A, B, C and D.

*MIL-L-23699 - oil used to wet the barrier (mesh) in the Permakleen™ Air Cleaner System. (Rev. A)

<u>Sample</u>	<u>Total Sodium (ppm)*</u>
-original MIL-H-5606	0.50
-original MIL-L-23699	0.52
-MIL-H-5606 from used impinger A	0.49
-MIL-H-5606 from used impinger B	0.89

Scientific & Laboratory Services Dept.

<u>Sample</u>	<u>Total Sodium (ppm)*</u>
-MIL-H-5606 from used impinger C	0.83
-MIL-H-5606 from used impinger D	0.67

*Note: Sodium content of sea water is approximately 14 mg/l. (ref. D. A. Livingstone, U.S. Geological Service. Prof. Pap. 440-G, 28 (1963) p. 41)

Discussion

The results of particle counting analysis on the MIL-H-5606 in impinger samplers A and B (i.e. land run) show that the Permakleen™ Air Cleaner is functioning properly in the LACV-30.

(Rev. A)

The table below provides calculated values of the number of particles per cubic foot of air at the inlet (i.e. impinger samples A) and outlet (i.e. impinger samples B) of the Permakleen™ system during the land run.

<u>Impingers</u>	<u>Number of Particles Per Cubic Foot of Air</u>						<u>(Rev. A)</u>
<u>Land Run</u>	<u>>1μ</u>	<u>>5μ</u>	<u>>10μ</u>	<u>>15μ</u>	<u>>25μ</u>	<u>>50μ</u>	<u>>100μ</u>
A	1,362,745.5	246,435.6	217,522.0	30,662.9	10,230.7	787.4	75.4
B	9,006.4	402.6	124.2	98.3	30.9	6.9	0.5

Based on the calculated values from the table above it is estimated that the Permakleen™ air cleaner was filtering more than 99.9 percent of solid particles larger than 10 microns. The numbers of particles larger than 10 microns in impinger B are within a range representative of background counts for these impingers. Consequently a 99.9% calculated filtration performance of the Permakleen™ system for particles larger than 10 microns is considered conservative.

The results of particle counting analysis on the MIL-H-5606 in used impingers C and D were complicated by coalescence of sea water droplets and subsequent evaporation of water to yield sea salt particles in the oil. Consequently, no conclusions regarding Permakleen™ filtration performance can be drawn from these samples (i.e. C and D). The results of analysis of total water content of the MIL-H-5606 in impingers C and D show that water content (82 to 84 ppm) was about the same as for original condition MIL-H-5606 (80 ppm). The low level of water in oil from impingers C and D is estimated to result from the evaporation of water in the impinger bowl because of the 17 inches (+) Hg vacuum in the bowl that maintains air flow through the impinger.

Scientific & Laboratory Services Dept.

The results of analysis of the oil samples for total sodium content show that levels were reduced about 2.65 times (*adjusted for baseline contamination*) from the common air inlet of the LACV-30 power system to the Permakleen™ system outlet. Based on the average level of sodium in sea water it is estimated that the equivalent of 0.2 milliliters of sea water was ingressing into the inlet stack per cubic foot of air taken in. At the point of outlet from the Permakleen™ system the sea salt equivalent of sodium levels indicates that about 0.07 milliliters of sea water was contained in one cubic foot of air taken in by the APU turbine. (Rev. A)

Conclusions and Recommendations

1. The results of testing show that the Permakleen™ Air Cleaner System in LACV-30 craft No. 1 is operating properly. The particle filtration performance of the Permakleen™ unit based on air sampling data is calculated to exceed, 99.9%.
2. The results of testing show that during the ocean run, inlet to outlet (of Permakleen™ system) sea salt levels were reduced about 2.6 times to a level equivalent to 0.07 milliliters sea water per cubic foot of air taken into the APU.
3. It is recommended that the Permakleen™ Air Cleaner System be implemented as the air intake filtration system for the APU in the LACV-30.



Daniel R. Uhr, Jr. Ph.D.

Staff Scientist

Pall Corporation


Pall Scientific and Laboratory
Services Department

DU:ds

Attachment(s)

PERMAKLEEN™ AIR CLEANER SYSTEM

LACV-30 INSTALLATION



1107

APPENDIX A

PALL

APPENDIX B

LAVC-30 Permakleen™ Air Cleaner System
Air Sampling Test

Sampling Method

The air sampling method employs an impinger device (for example drawing see Appendix D) designed to draw air (by vacuum) from the duct into the impinger at the same air flow velocity as in the duct. This sampling process is commonly referred to as isokinetic sampling.

The air (along with particulate contamination) entering the impinger/sampler is channeled to a small ("critical") orifice where air velocity increases to about 850 ft/sec. The flow of air from the critical orifice exits to a bowl containing a liquid (initially very clean). The high velocity of particles in the air stream exiting the critical orifice assures impingement and capture of particles in the liquid. The liquid (in this case MIL-H-5606, hydraulic fluid) with captured contaminants was subsequently analyzed to determine levels of contaminants.

A description of the four impingers and conditions of operation used in this field sampling are provided below.

Air Sampling
Impinger Code

Condition of Operation During Sampling

- | | |
|---|---|
| A | Placed inside the inlet stack during the land run (see Figure 1, Appendix B). The stack is a cylindrical duct with inside diameter at the level of sampling of about 46 inches. The impinger orifice has an inside diameter of 0.197 inches. The sizing of the impinger isokinetic sampling orifice assumes an air velocity in the duct of 34 ft/sec at the sampling point. |
| B | Placed at the outlet of the Permakleen™ unit (see Figure 2, Appendix B) during the land run. The point of sampling was within the bounds of the one inch wide, 8 inch diameter circular rim connecting the battery box and the duct work downstream of the Permakleen™ system. This impinger has an isokinetic sampling orifice of 0.125 inch diameter based on a calculated air flow velocity of 84 ft/sec in the duct at the point of sampling. |

Note: Sampling impingers A and B were in operation during the land run (85% engine power) for a total of 65 minutes on 6/17/86.

<u>Time</u>	<u>Model of Operation</u>
10:05 am	Startup of engines
10:15 am	Takeoff
10:25 am	Light dust run
10:50 am	Heavy dust run (see Figure 3, Appendix B)
10:50 - 11:05 am	Set-down and shut-down on beach.

APPENDIX B



Figure 1 Main Air Intake Inlet Stack Location - Impingers A and B
Air Sample Representative of Challenge to Permakleen
Air Cleaner System



Figure 2 Battery Box - Outlet of Permakleen Air Cleaner System
- Impingers C and D -

- C Placed inside the inlet stack during the beach and ocean run (see Figure 1, Appendix B). Other physical parameters were the same as for impinger A.
- D Placed at the outlet of the Permakleen™ unit (see Figure 2, Appendix B) during the beach and ocean run. Other physical parameters were the same as for impinger B.

Note: Sampling impingers C and D were in operation during the beach/ocean run (95.5% engine power) for a total of 41 minutes on 6/17/86:

<u>Time</u>	<u>Mode of Operation</u>
11:20 am	Startup of engines
11:35 am	Take-off over water (see Figure 4, Appendix B)
11:58 am	Set down on beach
12:01 pm	Shut down on beach



Figure 3 Moderate to Heavy Dust During Land Run -
 (i.e. Impingers A and B)



Figure 4 Water Mist During Ocean Run (i.e. Impingers C and D)

Appendix C

Analytical Procedures

All analytical procedures were performed in the facilities of the Scientific and Laboratory Services (SLS) Department of Pall Corporation in Glen Cove, New York.

1. Particle Counting

The procedure employed for counting contaminant particles in fluid samples parallels the industry-wide standard of S.A.E. ARP 598A, "The Determination of Particulate Contamination in Liquids by the Particle Count Method". A volume of sample fluid is drawn through a gridded, 0.8 micron, analysis membrane disc of 25mm diameter (2.8 cm² effective filtration area). Contaminant particles collected on the membrane surface are counted and sized using a Olympus BH2U optical microscope with an oblique lighting source.

2. Photomicrographs

Color photomicrographs of the contaminant collected on a representative area of the analytical membrane surface are obtained at 100X magnification. A Vanox polarizing microscope with camera attachment is employed for this purpose.

3. Water Content Determination


Water in oil is measured by the Karl Fischer method, per ASTM Standard D-1744. This procedure measures the total content of water in a portion of the oil sample, both dissolved and free. A Photovolt Aqua Test II Karl Fischer Analyzer is employed for this procedure.

In order to determine the amount of free water present, ten (10) milliliters of the fluid sample are centrifuged at 3500 rpm for 15 minutes at 77°F (25°C). If more than 1% (10,000 ppm) of water is present, the water layer formed during centrifugation is compared to the oil layer, and the proportion reported as percent free water. If less than 1% water, Karl Fischer analysis is performed on the centrifuged oil layer to determine the amount of water dissolved in the oil. Free water is then determined as:

$$\text{Free Water} = \text{Total Water} - \text{Dissolved Water}$$

Total Sodium Analysis

Atomic absorption spectroscopy was employed to analyze quantitatively for sodium content. These tests were conducted on oil from the use impingers and base-line oil samples (i.e. MIL-H-5606 and MIL-L-23699) by Schwarzkopf Microanalytical Laboratory, Woodside, New York. This test report is on file in Pall/SLS.



APPENDIX D

ITEM	QTY	DESCRIPTION	UNIT
10	1	CA IMPER 44	INLET NOZZLE
9	1	CA IMPER 400-6	1/4" UNICAL
8	1	CA IMPER 400-6	IMPINGER
7	1	CA IMPER 400-6	3/8" DIA. 1/2" DIA. 1/2" DIA.
6	1	CA IMPER 400-6	1/4" DIA. 1/2" DIA. 1/2" DIA.
5	1	CA IMPER 400-6	1/4" DIA. 1/2" DIA. 1/2" DIA.
4	1	CA IMPER 400-6	1/4" DIA. 1/2" DIA. 1/2" DIA.
3	1	CA IMPER 400-6	1/4" DIA. 1/2" DIA. 1/2" DIA.
2	1	CA IMPER 400-6	1/4" DIA. 1/2" DIA. 1/2" DIA.
1	1	CA IMPER 400-6	1/4" DIA. 1/2" DIA. 1/2" DIA.

PALL CORPORATION 100 BEACON AVENUE GLENCOE, N.Y. 11542	
AIR SAMPLING IMPINGER ASSEMBLY	
APPROVALS DRAWN BY FAROUK CHECKED BY [Signature] ENGINEER [Signature]	DATE 5/9/66 12/18/66 1/15/67
SIZE 5 1/2" DIA. C 06816 CC-1109-1	
DO NOT SCALE DRAWING	

UNLESS OTHERWISE SPECIFIED
 DIMENSIONS ARE IN INCHES
 TOLERANCES ARE
 FRACTIONS DECIMALS ANGLES
 + 1/16 .005 .02
 SURFACE FINISH 7
 BREAK EDGES .005 .020
 MATERIAL
 FINISH

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DO NOT SCALE DRAWING

DISTRIBUTION FOR REPORT NO. 2456

DEPARTMENT OF DEFENSE

- 1 Director, Technical Information
Defense Advanced Research Projects
Agency
1400 Wilson Blvd.
Arlington, VA 22209
- 1 Director
Defense Nuclear Agency
ATTN: TITL
Washington, DC 20305
- 2 Defense Technical Information Center
Cameron Station
ATTN: DTIC-FDAC
Alexandria, VA 22304-6145
- 1 Commander
US Army Aberdeen Proving Ground
ATTN: STEAP-MT-U (GE Branch)
Aberdeen Proving Ground, MD 21005
- 1 Director
US Army Materiel Systems
Analysis Agency
ATTN: AMXSY-MP
Aberdeen Prvng Ground, MD 21005-5071
- 1 Director
US Army Ballistics Research Laboratory
ATTN: AMXBR-OD-ST (STINFO)
Aberdeen Prvng Ground, MD 21005-5066
- 1 Director
US Army Engineer Waterways
Experiment Station
ATTN: Chief, Library Branch
Technical Information Center
Vicksburg, MS 39180

DEPARTMENT OF THE ARMY

- 1 HQDA (DAMA-AOA-M)
Washington, DC 20310
- 1 HQDA (DALO-TSM)
Washington, DC 20310
- 1 HQDA (DAEN-RDL)
Washington, DC 20314
- 1 HQDA (DAEN-MPE-T)
Washington, DC 20314
- 1 Commander
US Army Missile Research & Development
Command
ATTN: AMSMI-PR
Redstone Arsenal, AL 35809
- 1 Director
Army Materials and Mechanics
Research Center
ATTN: AMXMR-RL Technical Library
Watertown, MA 02172-0001
- 1 Commander
Chemical Research R&D Center
ATTN: SMCCR-SPS (Tech Library)
Aberdeen Prvng Ground, MD 21010-5423
- 1 Commander
US Army Armament Research &
Development Command
ATTN: SMCAR-TSS
Dover, NJ 07801-5001
- 1 Commander
US Army Troop Support & Aviation
Materiel Readiness Command
ATTN: DRSTS-MES (1)
4300 Goodfellow Blvd.
St. Louis, MO 63120
- 2 Director
Petrol & Fld Svc Dept
US Army Quartermaster School
Fort Lee, VA 23801
- 1 US Army Tank Automotive Command
ATTN: DRSTA-TSL
Warren, MI 48090

1 Commander
US Army Electronics Research &
Development Command
ATTN: DELSD-L
Fort Monmouth, NJ 07703-5301

1 President
US Army Aviation Test Board
ATTN: STEBG-PO
Fort Rucker, AL 36360

1 US Army Aviation School Library
PO Drawar O
Fort Rucker, AL 36360

1 HQ 193D Infantry Brigade (Pan)
ATTN: AFZU-FE
APO Miami 34004

2 Special Forces Detachment, Europe
ATTN: PBO
APO New York 09050

2 Engineer Representative
USA Research & Standardization
Group (Europe)
Box 65
FPO 09510

1 Commander
Rock Island Arsenal
ATTN: SARRI-LPL
Rock Island, IL 61299-7300

1 HQDA
ODCSLOG
DALO-TSE
Room 1E588, Pentagon
Washington, DC 20310-0561

1 Plastics Technical Evaluation Center
ARRADCOM, Bldg 3401
Dover, NJ 07801

1 Commandant
US Army Engineer School
ATZA-CDD
Fort Belvoir, VA 22060

1 President
US Army Airborne, Communications &
Electronics
ATTN: STEBF-ABTD
Fort Bragg, NC 28307

1 Commander
Headquarters, 39th Engineer Battalion
(Cbt)
Fort Devens, MA 01433

1 President
US Army Armor and Engineer Board
ATTN: ATZK-AE-PD-E
Fort Knox, KY 40121-5470

1 Commander and Director
USA FESA
ATTN: FESA-TS
Fort Belvoir, VA 22060

1 HW, USAEUR & Seventh Army
Deputy Chief of Staff, Engineer
ATTN: AEAEN-MT-P
APO New York 09403

1 Director
US Army TRADOC
Systems Analysis Activity
ATTN: ATAA-SL (Tech Lib)
White Sands Missile Range, NM 88002

BELVOIR RD&E CENTER

1 Commander STRBE-Z
Deputy Commander STRBE-ZD
Technical Director STRBE-ZT
Assoc Tech Dir (E&A) STRBE-ZTE
Assoc Tech Dir (R&D) STRBE-ZTR
Executive Officer STRBE-ZX
Sergeant Major STRBE-ZM
Advanced Systems Concept Dir STRBE-H
Program Planning Div STRBE-HP
Foreign Intelligence Div STRBE-HF
Systems and Concepts Div STRBE-HC
CIRCULATE

1 STRBE-F

1 STRBE-FR

15 STRBE-FRD

3 Tech Reports Ofc STRBE-BPG

3 Security Ofc (for liaison officers) STRBE-S

2 Tech Library STRBE-BT

1 Publics Affairs Ofc STRBE-I

1 Ofc of Chief Counsel STRBE-L

DEPARTMENT OF THE NAVY

- 1 Director, Physics Program (421)
Office of Naval Research
Arlington, VA 22217
- 2 Commander
Naval Facilities Engineering Command
Department of the Navy
ATTN: Code 032-B
062
200 Stovall St.
Alexandria, VA 22332
- 1 US Naval Oceanographic Office
Navy Library/NSTL Station
Bay St. Louis, MO 39522
- 1 Library (Code L08A)
Civil Engineering Laboratory
Naval Construction Battalion Center
Port Hueneme, CA 93043
- 1 Director
Earth Physics Program
Code 464
Office of Naval Research
Arlington, VA 22217
- 1 Naval Training Equipment Center
ATTN: Technical Library
Orlando, FL 32813

DEPARTMENT OF THE AIR FORCE

- 1 HQ USAF/RDPT
ATTN: Commander
Washington, DC 20330
- 1 HQ USAF/PREEU
Chief, Utilities Branch
Washington, DC 20330
- 1 US Air Force
HQ Air Force Engineering & Service Ctr
Technical Library FL7050
Tyndall AFB, FL 32403
- 1 Chief, Lubrication Br
Fuels & Lubrication Div
ATTN: AFWAL/POSL
800 Independence Ave., SW
Washington, DC 20591

END

DATE

FILMED

6-88

DTIC